

Measurement Tools & Verification of Savings Calculations

E. Savings calculation methods

E. Savings Calculation Methods

- What are the main M&V savings calculation methods?
 - Load and schedule method
 - Regression methods
 - Simulations
- How are they applied?
- What software and tools are available?

Load and Schedule Method

- Based on simple equations:

$$kWh_{saved} = kWh_{base} - kWh_{post}$$

- Variations

- Constant load, constant schedule (hours of use)

- EEM changes hours of use: $kWh_{saved} = kW(HRS_{base} - HRS_{post})$

- EEM changes load: $kWh_{saved} = (kW_{base} - kW_{post})HRS$

- Other equations exist for variable load

- Note how ‘adjustments’ are included in calculations:

- EEM changes hours of use – kW same in base and post

- EEM changes load – HRS same in base and post


Load and Schedule Method

- Procedure
 - Characterize baseline equipment load and schedule operation
 - Constant or Variable
 - Determine impact of EEM on load & schedule
 - Changes load or changes schedule or both
 - Characterize post-install operation
 - Define analysis algorithms (pick equation)
 - From equation, identify data required
 - Develop data collection plan
 - Data points (i.e. kW, HRS, etc.)
 - Spot measurement
 - Monitoring required

Load and Schedule


- Operation Categories
 - Four categories are used to characterize the operation characteristics of the end-uses:
 - Constant Load, Timed Schedule
 - Variable Load, Timed Schedule
 - Constant Load, Variable Schedule
 - Variable Load, Variable Schedule

Constant Load, Timed Schedule (CLTS)




- Degree of “constant” defined by user
 - Variation less than 5% may be OK
- Examples
 - Lighting under time clock control
 - CRAH unit fan 24/7 operation

Variable Load, Timed Schedule (VLTS)




- kW varies with load
 - kW varies based on cfm, ton, speed, etc.
- Total hours constant, distributed over several load bins
- Examples
 - WW treatment blowers maintaining constant DO levels (24/7)
 - CRAC unit operation (split system, condenser on roof)

Constant Load, Variable Schedule



- Load is constant, but unknown hours-of-use
- Examples:
 - Lighting controlled with occupancy sensors
 - Constant speed cooling tower fans – hours vary with ambient temperature

Variable Load, Variable Schedule



- Hours-of-use in each bin and total are unknown
- Examples
 - Chilled water system maintaining CHWST reset schedule
 - Industrial VFD compressed air system

Load and Schedule: Algorithm

1. Identify baseline operation category
2. Determine impact of EEM
 - a. Changes load, changes schedule
 - b. Changes load or schedule from constant to variable
3. Based on EEM impact, identify post-installation operation category
4. Select equation, define analysis procedure
5. Determine relationships between load & hours-of-use, and other parameters
 - e.g. T, cfm, gpm, speed, tons, etc.
6. Collect baseline and post-install data
7. Calculate savings

Load and Schedule - Applicability

- Loads that may be isolated and measured
 - Air or water flow, heating Btu/h, cooling tons, etc.
 - Relationship to kW known or may be developed
- Energy flows: there should be few and straightforward to measure
- There are negligible or ignorable interactive effects with other equipment

Equations

- Savings equation selected based on
 - Characteristics of equipment operation
 - Impact of ECM
- Select equation to minimize data requirements
 - e.g. lighting fixture replacement, constant hours-of-use
 - Measure kW in baseline period (not hours-of-use)
 - Measure kW and hours-of-use in post-install period

$$kWh_{saved} = (kW_{base} - kW_{post})HRS_{post}$$

Equations – Examples

- CLTS

- Changes load

$$kWh_{saved} = (Eff_{base} - Eff_{post}) \cdot Q_{post} \cdot HRS_{post}$$

- Changes hours-of-use

$$kWh_{saved} = kW_{base} \cdot (HRS_{base} - HRS_{post})$$

- Changes load from constant to variable

$$kWh_{saved} = kW_{base} \cdot HRS - \sum [kW_{post,i} \cdot HRS_i]$$

- Changes hours-of-use from constantⁱ to variable

$$kWh_{saved} = kW_{base} \cdot HRS_{base} - kW_{base} \sum_i HRS_{post,i}$$

$$HRS_{base} \neq HRS_{post} \quad HRS_{post} = \sum_i HRS_{post,i}$$

Equations – Examples, cont.

- VLTS

- Changes load

$$kWh_{saved} = \sum_i [kW_{base,i} \cdot HRS_{base,i} - kW_{post,i} \cdot HRS_{post,i}]$$
$$\sum_i HRS_{base,i} = \sum_i HRS_{post,i}$$

- Changes hours-of-use

$$kWh_{saved} = \sum_i kW_{base,i} HRS_{base,i} - \sum_i kW_{base,i} HRS_{post,i}$$
$$\sum_i HRS_{base,i} \neq \sum_i HRS_{post,i}$$

- Changes hours-of-use from constant to variable

$$kWh_{saved} = \sum_i kW_{base,i} HRS_{base,i} - \sum_j kW_j HRS_{post,j}$$
$$\sum_i HRS_{base,i} \neq \sum_j HRS_{post,j}$$

Equations – Examples, cont.

- CLVS

- Changes load

- $$kWh_{saved} = (kW_{base} - kW_{post}) \cdot HRS_{base} \text{ (or } HRS_{post} \text{)}$$

- Changes hours-of-use

- $$kWh_{saved} = Eff_{base} \cdot Q_{base} \cdot (HRS_{base} - HRS_{post})$$

- Changes load from constant to variable

- $$kWh_{saved} = kW_{base} \cdot HRS_{base} - \sum_i [kW_{post,i} \cdot HRS_{post,i}]$$

$$HRS_{base} = \sum_i HRS_{post,i}$$

Equations – Examples, cont.

- VLVS

- Changes load

$$kWh_{saved} = \sum_i [(kW_{base,i} - kW_{post,i}) \cdot HRS_{post,i}]$$

- Changes hours-of-use

$$kWh_{saved} = \sum_i [kW_{base,i} \cdot (HRS_{base,i} - HRS_{post,i})]$$

- Changes load and hours-of-use

$$kWh_{saved} = \sum_i [kW_{base,i} \cdot HRS_{base,i}] - \sum_i [kW_{post,i} \cdot HRS_{post,i}]$$

Simple Example

- A storage building at an Army Base is undergoing a lighting retrofit. The existing exterior lighting of the building consists of (9) 70W Metal Halide Wall pack fixtures.
- The following procedure complies with load and schedule approach and is used to determine project energy savings

Step1. – The existing fixtures produce a constant wattage and were observed to operate continuously day or night. Therefore the Constant Load Timed Schedule (CLTS) category best represents this existing equipment's load and hours-of-use characteristics.

Step2. – The ECM includes retrofitting the (9) 70W Metal Halide Wall pack fixtures with (9) 36W LED Wall pack fixtures and installing Daylight controls as shown in Table 1 and Table 2

Example, cont.

Table 1

Fixture	kW/Fixture	Qty	Hours of operation	Total kW
70W Metal Halide Wall pack	0.095	9	8,760	0.855

Table 2

Fixture	kW/Fixture	Qty	Hours of operation (estimated)	Total kW
36W LED Wall Pack	0.036	9	4,380	0.324

Example, conclusion

- Step 3. This ECM will reduce the equipment's load and hours of operation. The anticipated post-installation equipment's load and hours of use characteristics best fit into the CLVS category. Therefore, the appropriate equation to use in determining savings is:

$$kWh_{\text{saved}} = kW_{\text{existing}} \times HRS_{\text{existing}} - kW_{\text{proposed}} \times \sum HRS_{\text{proposed}}$$

- In review, the key parameters estimated were load and hours of use. Data sources for those parameters included nameplate information (in this case, the lamp label or model number), A Table of Standard Wattages, interviews with the facilities staff and a light logger.
- Total savings for this project were 6,071 kWh.

Advantages of L&S Method

- M&V is extension of methods used to calculate ex-ante savings
- Allows use of technical (not measured) info.
- Many required measurements may be cost-effectively obtained
- Can apply to more complicated systems, if operation characteristics same
- Can quantify savings uncertainty, if required

Disadvantages

- Not practical for multiple EEMs throughout a facility
- Does not account for savings interactions
 - e.g. cooling savings from a lighting retrofit
- Not well applied to end-uses with highly random load and schedule characteristics

Regression Method

- Empirical relationships between energy use and factors that influence energy use
 - Ambient temperature
 - Time (of year, of week, etc.)
 - Occupancy
 - Etc.
- Influencing parameters must be measurable

Regression Method

- General procedure
 - Develop a regression relationship between energy use and one or more independent variables using data from the baseline period
 - Check model quality – fit statistics, error
 - Using post-install data, determine ‘adjusted baseline’ in post-install period
 - Subtract actual energy use to determine savings (avoided energy use)

Monthly Bill Regression - Heating

- Based on monthly energy bills
- Calculate heating degree-days to determine the weather-induced load on the heating system
 - Requires a balance-point temperature, which is the temperature above which the building requires heating, and varies from building to building, typically 60 or 65F.

$$HDD = \sum_{day=1}^{month} (T_{bal} - \bar{T}_{ambient})_{day_i}$$

(toss out negative values)

Monthly Bill Regression - Cooling

- Calculate cooling-degree-days to determine the base load and weather-induced load on the cooling system
 - Also requires a balance point temperature above which cooling is required. Can be different than heating balance point temperature.
 - Due to internal heat gains, the T_{bal} may be much lower than ambient

$$CDD = \sum_{day=1}^{month} (\bar{T}_{ambient} - T_{bal})_{day_i} \quad (\text{toss out negative values})$$

Weather Data

- The NOAA website and other websites such as weather underground provide weather data including ambient dry-bulb temperature for many airports and other weather stations throughout the country.
 - www.noaa.gov
 - www.wunderground.com
- Values provided are generally on an hourly basis.
- Data must be checked, often there are gaps and erroneous values in the data
- Some site provide heating degree days directly
 - www.degree-days.net

Monthly Bill Regressions

- Most spreadsheet tools have a regression tool.
- Tabulate the monthly bills and HDD for each month in a spreadsheet.
- Also record the number of days each month.
- Use the regression tool to determine the linear regression's model coefficients and coefficient of determination (R^2)
- Also calculate the $CV(RMSE)$ – coefficient of variation of the root mean squared error

$$CV(RMSE) = 100 * \frac{\left[\sum_i (E_i - \hat{E}_i)^2 / (n - p) \right]^{1/2}}{\bar{E}}$$

Monthly Bill Regression: Brief Example

- Monthly Gas Bill Data (cu.ft.)


Date	Days	Natural Gas Consumption	Heating Degree-Days	Predicted Gas Consumption
4/7/2004	33	208,664	440	187,595
5/6/2004	29	157,866	220	149,476
6/5/2004	30	120,793	150	137,347
7/7/2004	32	116,508	50	120,020
8/7/2004	31	107,272	20	114,822
9/5/2004	29	95,411	14	113,782
10/6/2004	31	126,423	29	116,381
11/6/2004	31	149,253	125	133,015
12/4/2004	28	166,202	275	159,006
1/6/2005	33	221,600	590	213,586
2/5/2005	30	224,958	723	236,631
Total		1,694,950		1,681,661

Baseline Model Improvement

- Improve example linear model by:
 - Normalizing the data (divide Gas and HDD by no. days)
 - This “weights” the points by the number of days
- Perform regression on weighted values
 - Result: Gas = Days*(3,651+177*HDDPD)
 - NBE = -0.044% (was 0.8%)

Date	Days	Natural Gas Consumption	Heating Degree-Days	Nat Gas Use per Day	HDD per Day	Predicted Gas Use per Day	Predicted Gas Consumption
4/7/2004	33	208,664	440	6,323.2	13.33	6,004.8	198,160
5/6/2004	29	157,866	220	5,443.7	7.59	4,990.1	144,714
6/5/2004	30	120,793	150	4,026.4	5.00	4,533.5	136,005
7/7/2004	32	116,508	50	3,640.9	1.56	3,926.6	125,650
8/7/2004	31	107,272	20	3,460.4	0.65	3,764.6	116,703
9/5/2004	29	95,411	14	3,290.0	0.48	3,735.9	108,342
10/6/2004	31	126,423	29	4,078.2	0.94	3,815.9	118,292
11/6/2004	31	149,253	125	4,814.6	4.03	4,362.6	135,242
12/4/2004	28	166,202	275	5,935.8	9.82	5,384.8	150,774
1/6/2005	33	221,600	590	6,715.2	17.88	6,807.4	224,644
2/5/2005	30	224,958	723	7,498.6	24.10	7,905.8	237,174
Total		1,694,950					1,695,698


Baseline Model: Actual v. Predicted




$$\text{Gas Use} = \text{Days} * (3,651 + 177 * \text{HDDPD})$$

$$R^2 = 0.92, \text{CV(RMSE)} = 8.9\%$$

Adding Post-Installation Data



Baseline Projection & Savings



- Post-Installation Period Savings: 609,567 cu.ft. \pm 17%
- Savings percentage: 32%


Best Applications with Monthly Data

- Significant energy savings
 - Rule of thumb: 10-15% or more of consumption measured by the utility meter
- All parameters which significantly affect energy usage can be clearly identified (during baseline and after implementation)
- Adjustment factors are simple
- Individual ECM measurement is not required
- Multiple ECMs
- Complex ECMs


Energy Models based on Interval Data

- “Interval data” = data from Time-of-Use Meters, typically in very large commercial and industrial buildings.
- Smart Meters in smaller buildings and houses are now providing interval data.
- Interval data is energy use data from short time interval measurements, typically 15-minutes for electricity.

Short Time Interval Methods



M&V with Interval Data



Useful Software

- ASHRAE Inverse Modeling Toolkit (RP1050)
 - Purchase with Research Project 1050
- Energy Explorer
 - “Change-point” models
 - Source: Prof. Kelly Kissock, University of Dayton
- Energy Charting and Metrics Tool
 - www.northwrite.com
- PG&E Universal Translator M&V Analysis Module
 - www.utoonline.org (coming soon)

Calibrated Simulation

- A simulation of a building or system is made using a recognized software
 - eQUEST
 - EnergyPlus
 - EnergyPRO
- The building or system is ‘modeled’ within the software, and ‘calibrated’ with measured data from the building to make sure the model accurately predicts baseline energy use
- After EEMs are installed, the simulation is run with post-installation data (temperature, occupancy, etc.) to determine the adjusted baseline.
- Savings are determined by subtraction of the measured post-installation use from the adjusted baseline.

Calibrated Simulation

- Advantages
 - Can quantify individual EEM savings as well as whole building
 - Useful to have a simulation for other purposes
- Disadvantages
 - Can be most difficult and expensive method
 - Requires a lot of building data to calibrate
 - Simulation programs may model the building well

BEST Center Curricula, Resources & Recordings

Academic Programs

Georgia Piedmont Technical College - Building Automation Systems

Milwaukee Area Technical College - Sustainable Facilities Operations

Laney College - Commercial HVAC Systems

City College San Francisco - Commercial Building Energy Analysis & Audits

Professional Development Materials, Presentations & Videos

National Institutes

Building Automation Systems Instructor Workshops

Webinars (e.g., BEST Talks)

Faculty Profile Videos

Reports & Case Studies

Marketing Resources

© 2013-2025 by BEST Center: NSF National Center for Building Technician Education is licensed under Creative Commons Attribution-Non Commercial (CC BY-NC) 4.0 International.

To view a copy of this license, visit <https://creativecommons.org/licenses/by-nc/4.0/>

 CC BY-NC 4.0

Attribution-NonCommercial 4.0

